

OFFICE OF THE MUNICIPAL COUNCIL NALAGARH DISTT. SOLAN(HP)

PERFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION

CERTIFICATE


No. 616.....


Dated 20/5/25.....

It is certified that an inspection team headed by Sh Ranvir Singh Verma Executive officer & Sh Prabhat Sharma JE of Municipal Council , Nalagarh (Name of officers with designation) from office of the Municipal Council, Nalagarh (Name of department/Office) inspected the Sunshine Public School, Village Chuhuwal, Tehsil Nalagarh, Distt. Solan HP (Name & Address of School) Chuhuwal and found that the Sunshine Public School (Name of School) has safe drinking water facilities for the students and member of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the central/State/U.T. govt.
The above valid for a period of one year




Signature with seal


Executive officer,
Municipal Council,
Nalagarh (HP).



Manager
Sunshine Public School
Nalagarh District Solan
Himachal Pradesh



Principal
Sunshine Public School
Nalagarh District Solan
Himachal Pradesh

WATER TESTING LABORATORY NALAGARH

JSV SUB-DIVISION: NALAGARH

DISTRICT : SOLAN

Lab Ref.NO

Based Upon BIS : 10500-2012

Date:- 15-05-2025

Name and Address of Sender – SUNSHINE PUBLIC SCHOOL.

Name of District :- Solan Block :- Nalagarh Sub Division :- Nalagarh.

Gram Panchayat :- Chuhuwal Village :- Chuhuwal Location :- Nalagarh.

Source :- Bore well Habitation: - Nalagarh.


Date & Time of Collection :- 13-05-2025 Time :- 11:00 AM


Date & Time of Receipt at Laboratory :- 13-05-2025 Time :- 12:10PM


Date & Time of Commencing :- 13-05-2025 - 1:40PM


A.)	PHYSICAL TEST			
Sr.No.	TESTS	Desirable Limit	Permissible Limit	Actual Result
1	Temperature	12	15	13°c
2	Colour	5	15	7
3	Odour	Agreeable	Agreeable	Agreeable
4	Taste	Agreeable	Agreeable	Agreeable
5	Turbidity	1 NTU	5 NTU	3 NTU
6	TDS/ Conductivity	500 PPM	2000 PPM	501PPM
B.)	CHEMICAL TESTS			
7	CALCIUM	75	200	46.092mg/l
8	PH	6.5	8.5	7.43
9	Total Alkalinity	200 mg/l	600 mg/l	488.25 mg/l
10	Chlorides	250 mg/l	1000 mg/l	85.57mg/l
11	Fluoride	1.0 mg/l	1.5 mg/l	-----
12	Total Hardness	200 mg/l	600 mg/l	460mg/l
13	Magnesium	30 mg/l	100 mg/l	99.2 mg/l
14	Residual chlorine	0.2 mg/l	1 mg/l	-----
8C	BACTERIOLOGICAL TEST:-			
15	Total coli from Count (TCC)	0 MPN	0 MPN	-----
16	E-coli Form/Thermo-tolerant Coli Form	0 MPN	0 MPN	0MPN


REMARKS:- OBSERVATIONS ARE WITHIN LIMITS


Assistant Chemist
Water Testing Lab Nalagarh


Junior Engineer
JSV Section Nalagarh


Assistant Engineer
JSV Sub Division Nalagarh


Manager
Sunshine Public School
Nalagarh District Solan
Himachal Pradesh


Principal
Sunshine Public School
Nalagarh District Solan
Himachal Pradesh